

Adjusting Slab Guardrail Post

A1 TESTING



Report NUMBER: 102337600COQ-001

Original Issue Date: October 28, 2015

A1 Type 1.067M (42'')			
Test No.	[lbf]	[kN]	[kgf]
1	337	1.5	153
2	387	1.72	175
3	361	1.6	164
4	371	1.65	168

B TESTING



Report NUMBER: 101927638COQ-001


Original Issue Date: January 5, 2015

B Type 1.067M (42'')			
Test No.	[lbf]	[kN]	[kgf]
1	428	1.9	194
2	399	1.77	181
3	402	1.79	182
4	412	1.83	187


OSHA Standard: A Force of at least 200(lbs) / 0.89(kN) / 90.72(kg)

- CAN/CSA-S269.2-M87 (Reaffirmed 2003), Access Scaffolding for Construction Purposes, Section 5.5.2 Posts
- Canada Occupational Health and Safety Regulations, Section 3.8(2) Guardrails and Toe Boards (Temporary Structures)
- Occupational Safety & Health Administration (OSHA), Section 1926.502(b)(3) Safety and Health Regulations for Construction - Fall Protection


Reported by:


Chris Chang, P. Eng.
Engineer, Building Products

Reviewed by:


Riccardo DeSantis
NORTH AMERICA Manager,
Building Products

Reviewed by:


Dan Lungu, P. Eng.
Engineer,
Manufactured Housing
